

**Date:** 29 December 2015

**Ref.:** Proc./253/1215

**Bid no.:** BID-090-GOO-ICB/15

**Bid Name:** Procurement of Electrical Generators, Distribution Transformers, Electrical Panels & Cables

**Subject:** Tender Clarifications Letter #3

To whom it may concern,

Please find below questions received from one of the suppliers & our reply:

Question No. Item No.	Questions	Clarifications
<b>Q: 1</b> <b>Section VI:</b> Schedule of Requirements Technical Specifications and Compatibility Table LOT 1 -Generators <b>Page:</b> 62 - 116	It is not stated whether the generators should be with or without cabin in technical specifications for LOT 1: Generators. We kindly require you to provide information on this issue.	These generators will be installed indoors as it is stated in the Technical Specifications and Compatibility Table. Therefore, they must be " <b><u>without cabin</u></b> " type.

We are looking forward to receive your offers before the deadline of submission.

Best Regards,



**Hani Khabbaz**

Director General

Management Unit

Syria Recovery Trust Fund